

# TYPE APPROVAL CERTIFICATE

**This is to certify:****That the Electric Power Cable**

with type designation(s)

**RU P18 0,6/1 kV**

Issued to

**Helkama Bica Oy  
Kaarina, Finland**

is found to comply with

**Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards****IEC 60092-353 (2011-08)****IEC 60332-3-22 (2009-02)****IEC 60754-1/2 (2011-11)****IEC 61034-1/2 Ed. 3.1 (2013-06)****NEK TS 606 (2009-05)****Application :****General power and lighting. Control.****Flame retardant in bunch Cat. A. Halogen free. Low smoke.****Mud resistant.****Voltage class (kV) 0,6/1  
Temp. class (°C) 90**This Certificate is valid until **2019-06-30**.Issued at **Høvik** on **2015-06-01**DNV GL local station: **Turku**for **DNV GL**Approval Engineer: **Ivar Bull****Marit Laumann  
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

If any person suffers loss or damage which is proven to have been caused by any negligent act or omission of the Society, then the Society shall pay compensation to such person for his proven direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question. The maximum compensation shall never exceed USD 2 million.

In this provision the "Society" shall mean DNV GL AS as well as all its direct and indirect owners, affiliates, subsidiaries, directors, officers, employees, agents and any other person or entity acting on behalf of DNV GL AS.

Certificate No: **E-14374**  
 File No: **827.10**  
 Job Id: **262.1-018083-1**

## Product description

Type: RU P18 0,6/1 kV

Construction:

Conductors: Tinned, stranded copper class 2 (or class 5)  
 Core insulation: EPR  
 Outer sheath: SHF2 or SHF2 Mud

No of cores:	Cross sectional area [mm <sup>2</sup> ]
1	1,5 - 400
2	1,5 - 240
3	1,5 - 300
4	1,5 - 300
5	1,5 - 300
7, 10, 14, 19, 24, 30, 37	1 1,5 2,5

## Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

## Type Approval documentation

Data sheet : See approval letter

Test reports: See approval letter

## Tests carried out

Standard	Issued	General description	Limitation
IEC 60092-350	2008-02	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	
<i>IEC 60092-353</i>	<i>2001-04</i>	<i>Single and multicore non-radial field power cables with extruded solid insulation for rated Voltages of 1 kV and 3 kV</i>	
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Bunch test Category A
IEC 60754-1	1994-01	Test on gases evolved during combustion of materials from cables – Determination of the amount of halogen acid gas	Low Halogen: <0,5% Halogen
IEC 60754-2	1999-07	Test on gases evolved during combustion of materials from cables – Determination of the degree of acidity of gases evolved during the combustion of materials taken from electric cables by measuring pH and conductivity	Halogen free: pH > 4,3 Conductivity < 10 µS
IEC 61034-1/2	2005-04	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke
NEK 606 Ed. 4	2009-05	Cables for offshore installations. Halogen-	Mud resistance test:

Certificate No: **E-14374**  
File No: **827.10**  
Job Id: **262.1-018083-1**

Standard	Issued	General description	Limitation
		free and/or mud resistant. Technical specification.	IRM903 100°C 7d. Calcium Bromide 70°C 56d. <u>Oil based mud:</u> Carbo Sea 70°C 56d or EDC 95/11 70°C 56d

### Marking of product

Helkama Bica Oy – RU P18– size – 0,6/1 kV – IEC 60332-3-22 - month - year

### Periodical assessment

The scope of the retention/renewal survey is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer’s product type marking and Type Approval Certificate.

Survey to be performed at least every second year.

END OF CERTIFICATE